



Department of Health and Human Services
Health and Environmental Testing Laboratory

221 State Street
#12 State House Station
Augusta, ME 04333-0012
Phone: (207)287-2727 Fax: (207)287-6832
TTY: 1-800-606-0215
EPA ID: ME00002

COUTURE, WILLIAM
NEW ENGLAND MUSIC CAMP
8 GOLDENROD LANE
SIDNEY ME 04330

E&PAC = ALUMNI HALL
& EDUCATION BUILDINGS

Logged: 09/28/2020 9:49:05AM

Folder/ Invoice #: 2004376

Office Use Only: 300899 Public
--

Released: 10/7/2020

Case #:

Project Name:

No. of Samples in Folder 1
2004376-01

CERTIFICATION

The HETL hereby certifies that all test results for this sample were analyzed by the method listed, including preservation, preparation, and holding times, unless otherwise indicated.

Kenneth G. Pote, PhD., Director

Richard French, Quality Assurance Officer

If we can be of further assistance to you, please call us at 287-1716.

Approved by:

James E. Curlett
Organics Supervisor/Chemist III

Continued from Previous Page

HTL Sample Number: 2004376-01

Description: AFTER WELL & BEFORE DISTRIBUTION

Matrix: Drinking Water - ALUMNI HALL

Sample Point: WL-1

Sampler: BRYAN STAFFIERI

Sample Date: 9/28/2020

Time: 08:30:00

Method: 524.2

Analyst: Vera Maheu

Analysis Date/Time: 09/30/2020 10:06:00

Analyte	Result	Units	RL	MCL	Qualifiers
1,1,1-Trichloroethane	<0.5	ug/L	0.5	200	
1,1,2-Trichloroethane	<0.5	ug/L	0.5	5	
1,1-Dichloroethene	<0.5	ug/L	0.5	7	
1,2,4-Trichlorobenzene	<0.5	ug/L	0.5	70	
1,2-Dichlorobenzene	<0.5	ug/L	0.5	600	
1,2-Dichloroethane	<0.5	ug/L	0.5	5	
1,2-Dichloropropane	<0.5	ug/L	0.5	5	
1,4-Dichlorobenzene	<0.5	ug/L	0.5	75	
Benzene	<0.5	ug/L	0.5	5	
Carbon Tetrachloride	<0.5	ug/L	0.5	5	
Chlorobenzene	<0.5	ug/L	0.5	100	
cis-1,2-Dichloroethene	<0.5	ug/L	0.5	70	
Dichloromethane	<0.5	ug/L	0.5	5	
Ethylbenzene	<0.5	ug/L	0.5	700	
m,p-Xylenes	<1	ug/L	1		
Methyl tert-Butyl Ether	<1	ug/L	1		
o-Xylene	<0.5	ug/L	0.5		
Styrene	<0.5	ug/L	0.5	100	
Tetrachloroethene	<0.5	ug/L	0.5	5	
Toluene	<0.5	ug/L	0.5	1000	
Total Xylenes	<1.5	ug/L	1.5	10000	
trans-1,2-Dichloroethene	<0.5	ug/L	0.5	100	
Trichloroethene	<0.5	ug/L	0.5	5	
Vinyl Chloride	<0.5	ug/L	0.5	2	

Surrogate Analytes (added as part of testing to verify performance)	Result	Amount	% Rec	Low % Rec	High % Rec	Qualifiers
1,2-Dichlorobenzene-d4	4.93	5.0	98.6	70	130	
4-Bromofluorobenzene	4.49	5.0	89.8	70	130	