



Department of Health and Human Services  
Health and Environmental Testing Laboratory  
221 State Street  
#12 State House Station  
Augusta, ME 04333-0012  
Phone: (207)287-2727 Fax: (207)287-6832  
TTY: 1-800-606-0215  
EPA ID: ME00002

COUTURE, WILLIAM  
NEW ENGLAND MUSIC CAMP KITCHEN  
8 GOLDENROD LANE  
SIDNEY ME 04330

*2 LODGE*

**Logged:** 09/28/2020 9:58:57AM

**Folder/ Invoice #:** 2004377

Office Use Only: 400899 Public
--------------------------------------

**Released:** 10/7/2020

Case #:

Project Name:

No. of Samples in Folder 1

2004377-01

## CERTIFICATION

The HETL hereby certifies that all test results for this sample were analyzed by the method listed, including preservation, preparation, and holding times, unless otherwise indicated.

Kenneth G. Pote, PhD., Director

Richard French, Quality Assurance Officer

If we can be of further assistance to you, please call us at 287-1716.

Approved by:

James E. Curlett  
Organics Supervisor/Chemist III

Continued from Previous Page

HETL Sample Number: 2004377-01

Description: AFTER WELL & BEFORE DISTRIBU

Matrix: Drinking Water

Sample Point: WL-3

Sampler: BRYAN SAFFIERI

Sample Date: 9/28/2020

Time: 08:00:00

Method: 524.2

Analyst: Vera Maheu

Analysis Date/Time: 09/30/2020 10:33:00

Analyte	Result	Units	RL	MCL	Qualifiers
1,1,1-Trichloroethane	<0.5	ug/L	0.5	200	
1,1,2-Trichloroethane	<0.5	ug/L	0.5	5	
1,1-Dichloroethene	<0.5	ug/L	0.5	7	
1,2,4-Trichlorobenzene	<0.5	ug/L	0.5	70	
1,2-Dichlorobenzene	<0.5	ug/L	0.5	600	
1,2-Dichloroethane	<0.5	ug/L	0.5	5	
1,2-Dichloropropane	<0.5	ug/L	0.5	5	
1,4-Dichlorobenzene	<0.5	ug/L	0.5	75	
Benzene	<0.5	ug/L	0.5	5	
Carbon Tetrachloride	<0.5	ug/L	0.5	5	
Chlorobenzene	<0.5	ug/L	0.5	100	
cis-1,2-Dichloroethene	<0.5	ug/L	0.5	70	
Dichloromethane	<0.5	ug/L	0.5	5	
Ethylbenzene	<0.5	ug/L	0.5	700	
m,p-Xylenes	<1	ug/L	1		
Methyl tert-Butyl Ether	<1	ug/L	1		
o-Xylene	<0.5	ug/L	0.5		
Styrene	<0.5	ug/L	0.5	100	
Tetrachloroethene	<0.5	ug/L	0.5	5	
Toluene	<0.5	ug/L	0.5	1000	
Total Xylenes	<1.5	ug/L	1.5	10000	
trans-1,2-Dichloroethene	<0.5	ug/L	0.5	100	
Trichloroethene	<0.5	ug/L	0.5	5	
Vinyl Chloride	<0.5	ug/L	0.5	2	

Surrogate Analytes (added as part of testing to verify performance)	Result	Amount	% Rec	Low % Rec	High % Rec	Qualifiers
1,2-Dichlorobenzene-d4	4.63	5.0	92.6	70	130	
4-Bromofluorobenzene	4.35	5.0	87	70	130	